For Residential and Commercial Applications

| Job Name | Contractor |
|--------------|-----------------------|
| Job Location | Approval |
| Engineer | Contractor's P.O. No. |
| Approval | Representative |

SmartTrac[™]

Radiant Panel Solution

Watts Radiant's SmartTrac[™] is a non-structural, modular board designed for subfloor, wall and ceiling radiant heating and cooling applications. It is manufactured from 5/8" (15.88 mm) thick MDF (medium density fiberboard) and is designed for use with ³/₈" (9.5 mm), ASTM F876 PEX or ASTM F2623 PERT.

Standard Panel

| DESCRIPTION | PROPERTY |
|------------------|---|
| Per panel weight | 8.95 lbs (4.06 kg) |
| Dimensions | 24" x 24" x 5/8" (610 mm x 610 mm x 15.88 mm) |
| Tube spacing | 8" (203.2 mm) 0.C. |

PROPERTY

Utility Panel (Optional)

| DESCRIPTION | |
|------------------|--|
| Per panel weight | |
| Dimensions | |
| Tube spacing | |

8.65 lbs (3.92 kg) 24" x 24" x ⁵/s" (610 mm x 610 mm x 15.88 mm) 4" (101.6 mm) 0.C.

MDF Technical Data

| DESCRIPTION | PROPERTY |
|---------------------|---|
| Density | 46 lb/ft ³ (7.4 kg/mm ³) |
| Internal Bond | 130 lb/in² (896 kPa) |
| Screw Holding, Face | 225 lbs (102 kg) |
| Screw Holding, Edge | 200 lbs (91 kg) |
| Flame Spread Rating | Class 3 (C) |
| Moisture Content | 4 - 6% |
| Thickness Swell | 5% |
| Linear Expansion | 0.3% |
| Approvals | Awarded CARB ULEF Exemption. |
| | Products meet CARB ATCM 93120 Phase 2 emission requirements. |
| | Meets physical properties of ANSI A208.2-2009 Grade 130 |

Average physical properties for %" (19 mm) panel, based on a 5 panel average, when tested in accordance with ASTM D1037. Emissions tested in accordance with ASTM E-1333.

U.S. Patent # 6,533,185 and Patents Pending





Standard Panel

Utility Panel (Optional)

A WARNING

SmartTrac[™] must be installed in accordance with all Watts Radiant installation procedures, including information provided in Watts Radiant's SmartTrac[™] Installation Manual.

Ensure that accurate room-by-room heat loss analysis is completed prior to installation.

For installation over wood subfloor, ensure subfloor is dry and flat according to guidelines in installation manual.

For installation over concrete slab, moisture considerations must be carefully addressed. It is strongly recommended that all slabs below grade and slabs on grade be sealed against moisture penetration.

Finished flooring options above SmartTrac[™] include hardwood, engineered wood, laminate, tile or stone with thinset, vinyl or carpet. Details for installation are included in the manual.

| Product Options | | |
|--------------------------|---------------|----------|
| Description | Model# | Order# |
| Standard Panel | ST838-0NE | 81016822 |
| Utility Panel (Optional) | ST838-UTILITY | 81016823 |

A CAUTION

This Engineering Sheet is not intended to provide full installation instructions and safety information. In order to avoid property damage or injury, please refer to the complete installation manual and product safety information provided with the product.

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.



USA: T: (800) 276-2419 • F: (417) 864-8161 • Watts.com Canada: T: (905) 332-4090 • F: (905) 332-7068 • Watts.ca Latin America: T: (52) 81-1001-8600 • Watts.com