UL 723/ASTM E84 Certificate

Acid Waste Submittal



Underwriters Laboratories, Inc.

Northbrook, IL Santa Clara, CA Melvillve, NY Research Triangle, NC an independent, non profit organization of public safety

CERTIFICATE I

Mfr.'s Ref No. <u>R15537</u> Control No. <u>1P91</u>

Orion Fittings, Inc., 2850 Fairfax Trafficway, Kansas City, KS 66115 is qualified under the classification and Follow-up Services of Underwriters Laboratories Inc. to furnish molded plastic, Classified as to Surface Burning Characteristics. This manufacturer is therefore authorize to issue this Certificate for the bulk shipment of material described below as it's representation that such material is manufactured in compliance with the requirements established by Underwrites Laboratories, Inc. for this class of product. This certificate does not indicate proper application of installation of the units and does not apply to other material, which may be used at the location specified.

Trade Name: Orion "Super Blue" and "Plenum Plus®" PVDF Pipe and Fittings

Classification:

Underwriters Laboratories, Inc. Classified Molded Plastic Surface Burning Characteristics UL 723 (ASTM E-84)

> Flame Spread: 5 Smoke Developed: 35