## Submittal Package

# Engineering Specification, Installation, Operation and Maintenance Series LFM114-1 / LFM6114-1

### Rate-of-Flow Control Valve with Solenoid On-Off

Sizes: 11/4" to 24"

#### **A** WARNING



Read this Manual BEFORE using this equipment.
Failure to read and follow all safety and use information can result in death, serious personal injury, property damage, or damage to the equipment.
Keep this Manual for future reference.

#### **A WARNING**

Local building or plumbing codes may require modifications to the information provided. You are required to consult the local building and plumbing codes prior to installation. If the information provided here is not consistent with local building or plumbing codes, the local codes should be followed. This product must be installed by a licensed contractor in accordance with local codes and ordinances.




**Need for Periodic Inspection/Maintenance:** This product must be tested periodically in compliance with local codes, but at least once per year or more as service conditions warrant. All products must be retested once maintenance has been performed. Corrosive water conditions and/or unauthorized adjustments or repair could render the product ineffective for the service intended. Regular checking and cleaning of the product's internal and external components helps assure maximum life and proper product function.

#### NOTICE

For Australia and New Zealand: Pipeline strainers should be installed between the upstream shutoff valve and the inlet of the backflow preventer.

It's important that this device be tested periodically in compliance with local codes, but at least once per year or more as service conditions warrant. If installed on a fire sprinkler system, all mechanical checks, such as alarm checks and backflow preventers, should be flow tested and inspected internally in accordance with NFPA 13 and NFPA 25.



LFM114-1

Table of Contents	Paga
Table of Contents	Page
Engineering Specifications	
ACV Schematic	2
Basic Valves	3
Standard Components	7
Optional Components	12
Installation, Operation and Maintenance	
Installation.	16
Valve Servicing Dimensions	16
Setting the Rate-of-Flow Controls	17
ACV Maintenance Schedule	19
Troubleshooting Guide	20
Valve Disassembly Instructions	21



## **Engineering Specification**

## LEAD FREE\*

## Series LFM114-1

### Rate-of-Flow Control Valve with Solenoid On-Off

### Full Port Ductile Iron Single Chamber Valve

#### **Features**

- Throttles to maintain constant rate-of-flow
- Solenoid (On-Off) Feature provides electrical override of valve function
- Adjustable Closing Speed
- Orifice Plate Assembly is remote mounted (field installed)
- Rate-of-Flow setpoint is adjustable

#### **Standard Components**

- 1 Main Valve (M100 Single Chamber)
- 2 Rate-of-Flow Control
- 3 2-Way Solenoid
- 4 Adjustable Closing Speed
- 5 Orifice Plate Assembly
- X Isolation Cocks

#### **Options and Accessories**

- O FC Flo-Clean Strainer
- O Y Y-Strainer (Replaces Flo-Clean)
- O AOS Adjustable Opening Speed
- O P Position Indicator
- O L Limit Switch


### Operation

The Rate-of-Flow Control ACV with Solenoid (On-Off) Feature is designed to automatically limit flow rate to a constant, adjustable, maximum, and open, allowing flow control action, or close drip-tight as commanded by the Solenoid Pilot. It is controlled by a normally open, differential control pilot designed to: 1) Open (allowing fluid out of the main valve cover chamber) when the differential pressure across the orifice plate is below its adjustable set point, and, 2) Close (allowing fluid to fill the main valve cover chamber) when the differential pressure across the orifice plate is above its adjustable set point. A decrease in differential pressure causes the valve to modulate towards an open position, increasing flow rate. An increase in differential pressure causes the valve to modulate towards a closed position, decreasing flow rate.

The Solenoid Pilot will either open to allow regulating action, or close the valve drip-tight when energized. Specify energize to open or close the Main Valve and voltage PRIOR to ordering.

The Orifice Plate Assembly should be installed three to five pipe diameters downstream of the Rate-of-Flow Valve, and field connected with %" minimum copper tubing in accordance with factory piping schematic.

Please specify desired flow rate prior to ordering.



\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

#### NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

## **M Series Basic Valves**

## Rate-of-Flow Control Valve with Solenoid On-Off

### Full Port Ductile Iron Single Chamber Basic Valve

This Watts Automatic Control Valve (ACV) is a full port, single chamber basic valve that incorporates a one-piece disc and diaphragm assembly. This assembly is the only moving part within the valve allowing it to open, close, or modulate as commanded by the pilot control system.

Watts ACV Main Valves are Lead Free. The Watts ACV piloting system contains Lead Free\* components, ensuring all of our configurations are Lead Free compliant.

Globe Pattern Single Chamber Basic Valve (M100) Angle Pattern Single Chamber Basic Valve (M1100)

#### Standard Materials

**Body and Cover:** Ductile Iron ASTM A536

Coating: NSF Listed Fusion Bonded Epoxy

Lined and Coated

Trim: 316 Stainless Steel

Elastomers: Buna-N (standard)

EPDM (optional) Viton™ (optional)

Nut, Spring and Stem: Stainless Steel

Anti-Scale (Optional): Xylan Coated Stem and Seat

Viton™ is a trademark of The Chemours Company FC, LLC

### **Operating Pressure**

Threaded = 400psi (27.6 bar) 150# Flanged = 250psi (17.2 bar) 300# Flanged = 400psi (27.6 bar) Grooved End = 400psi (27.6 bar)

#### **Operating Temperature**

Buna-N: 160°F (71°C) Maximum EPDM: 300°F (140°C) Maximum Viton™: 250°F (121°C) Maximum

Epoxy Coating\*\*: 225°F (107°C) Maximum

\*\* Valves can be provided without internal epoxy coating consult factory

### **Basic Valve Body Options**



Globe Flanged



Angle Flanged



Globe Grooved End



Angle Grooved End



Globe Threaded




Angle Threaded

#### Flow Data

	Valve Size - Inches	11/4	1½	2	2½	3	4	6	8	10	12	14	16
ted	Maximum Continuous Flow Rate Gpm (Water)	95	130	210	300	485	800	1850	3100	5000	7000	8500	11100
Suggested	Maximum Intermittent Flow Rate Gpm (Water)	119	161	265	390	590	1000	2300	4000	6250	8900	10800	14100
S	Minimum Flow Rate Gpm (Water)	3	5	6	9	15	16	17	25	55	70	190	400
>	Cv Factor GPM (Globe)	26	26	48	75	112	188	387	764	1215	1734	2234	3131
ػ	Cv Factor GPM (Angle)	26	27	57	91	125	207	571	889	1530	1945		

- Maximum continuous flow based on velocity of 20 ft. per second.
- Maximum intermittent flow based on velocity of 25 ft. per second.
- Minimum flow rates based on a 20-40 psi pressure drop.
- The  $C_v$  Factor of a value is the flow rate in US GPM at  $60^{\circ}$ F that will cause a 1psi drop in pressure.
- C<sub>v</sub> factor can be used in the following equations to determine Flow (Q) and Pressure Drop (ΔP):
  - Q (Flow) =  $C_v \sqrt{\Delta P}$
- $\Delta P$  (Pressure Drop) =  $(Q/C_v)^2$
- The C<sub>v</sub> factors stated are based upon a fully open valve.
- Many factors should be considered in sizing control valves including inlet pressure, outlet pressure and flow rates.
- For sizing questions including cavitation analysis consult Watts with system details.




### Valve Cover Chamber Capacity

Valve Size - Inches	11/4	1½	2	2½	3	4	6	8	10	12	14	16
fl.oz.	4	4	4	10	16	22	70					
U.S. Gal								11/4	2½	4	6½	9½

### Valve Travel


Valve Size - Inches	11/4	1½	2	2½	3	4	6	8	10	12	14	16
Travel - Inches	3/8	3/8	1/2	5/8	3/4	1	1½	2	21/2	3	3½	4

### **Basic Valve**



i i								
Pipe Plug	Lead Free Brass							
Cover	ASTM A536 65-45-12 Epoxy Coated Ductile Iron							
Cover Bearing	ASTM A276 304 Stainless Steel							
Stud with Cover Nut and Washer	ASTM A570 Gr.33 Zinc Plated Steel							
Body	ASTM A536 65-45-12 Epoxy Coated Ductile Iron							
Spring	ASTM A276 302 Stainless Steel							
Stem Nut	ASTM A276 304 Stainless Steel							
Lock Washer	ASTM A276 304 Stainless Steel							
Stem Washer	ASTM A276 304 Stainless Steel							
Diaphragm Washer	ASTM A536 65-45-12 Epoxy Coated Ductile Iron							
Diaphragm*	Buna-N (Nitrile)							
Disc Retainer	ASTM A536 65-45-12 Epoxy Coated Ductile Iron							
Seat Disc*	Buna-N (Nitrile)							
Spacer Washer* x5	NY300 Fiber*							
Disc Guide	ASTM A743 CF8M (316) Stainless Steel							
Shaft	ASTM A276 304 Stainless Steel							
Seat Ring**	ASTM A743 CF8M (316) Stainless Steel							
Seat Screw** (8" and Larger)	ASTM A276 304 Stainless Steel							
Seat Gasket*	Buna-N (Nitrile)							
	Cover Cover Bearing Stud with Cover Nut and Washer Body Spring Stem Nut Lock Washer Stem Washer Diaphragm Washer Diaphragm* Disc Retainer Seat Disc* Spacer Washer* x5 Disc Guide Shaft Seat Ring** Seat Screw** (8" and Larger)							


\* Contained in Main Valve Repair Kit \*\*Note: 6 inch and Smaller Valves, Seat Ring is threaded



### NOTICE

Installation: If unit is installed in any orientation other than horizontal (cover up) OR extreme space constraints exist, consult customer service prior to or at the time of order.

## **Dimensions**



#### Flanged and Threaded Dimensions

Valve Size	Globe '	Thread	Globe	150#	Globe	300#		er To nter	Angle	Thread	Angle	150#	Angle	300#	Angle '	Thread	Angle	150#	Angle	300#	Port Size NPT	Port Size NPT	Ship Weig	
	1	4	E	3		)	[	)		Ē	F	F	(	ì	I	1			,	J	K	L		
in.	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	in.	lbs.	kgs.
11/4	71/4	184					5½	140													3/8	1/4	20	9
1½	71/4	184	8½	216			5½	140	31/4	83					1%	48					3/8	1/4	25	11
2	9%	238	9%	238	10	254	6¾	171	4¾	120	4¾	121	5	127	31/4	83	31/4	83	3½	89	3/8	1/2	40	18
2½	11	279	11	279	11%	295	7½	191	5½	140	5½	140	5%	149	4	102	4	102	45/16	110	1/2	1/2	65	29
3	12½	318	12	305	131/4	337	81/4	210	61/4	159	6	152	6%	162	41/2	114	4	102	4%	111	1/2	1/2	95	43
4			15	381	15%	397	10%	270			7½	191	7%	200			5	127	55/16	135	3/4	3/4	190	86
6			20	508	21	533	13	330			10	254	10½	267			6	152	6½	165	3/4	3/4	320	145
8			25%	645	26%	670	16	406			12¾	324	131/4	337			8	203	8½	216	1	1	650	295
10			29¾	756	31%	791	17	430			14%	378	15%16	395			8%	219	95/16	237	1	1	940	426
12			34	864	35½	902	20%	530			17	432	17¾	451			13¾	349	14½	368	1	11/4	1500	680
14			39	991	40½	1029	241/4	616													1	1½	1675	760
16			41%	1051	431/2	1105	251/4	640													1	2	3100	1406

#### **Grooved End Dimensions**

Valve Size	Globe Grooved		Cover To Center		Angle Grooved		Angle Grooved		Port Size (npt)	Port Size (npt)	Shipping	Weights*
	1	4	В		C		D		Е	F		
in.	in.	mm	in.	mm	in.	mm	in.	mm	in.	in.	lbs.	kgs.
11/4	8½	216	5½	140	41/4	108	31/4	83	3/8	1/4	25	11
1½	8½	216	5½	140	41/4	108	31/4	83	3/8	1/4	25	11
2	9	229	6½	165	4¾	121	31/4	83	3/8	1/2	40	18
21/2	11	279	7½	191	51/2	140	4	102	1/2	1/2	65	29
3	12½	318	81/4	210	6	152	41/4	108	1/2	1/2	95	43
4	15	381	10%	270	7½	191	5	127	3/4	3/4	190	86
6	20	508	13%	340					3/4	3/4	320	145
8	25%	645	16	406					1	1	650	295

## **LEAD FREE\***

## **Model LFCP14-1**

### Rate-of-Flow Pilot

Size: %" NPT

The Model LFCP14-1 is a direct acting, diaphragm actuated Pilot that senses and responds to changes in a differential pressure signal. The differential pressure signal is usually created by an orifice plate located inline either upstream or downstream of the Main Valve. The Pilot has two sensing chambers, one above and one below the diaphragm. The "low" pressure signal is sensed above the diaphragm, and the "high" pressure signal is sensed below the diaphragm.

An increase in flow rate causes the differential pressure across the orifice plate to increase. The Pilot modulates toward a closed position when the differential pressure signal increases above the control setpoint, causing the Main Valve to modulate toward a closed position, decreasing flow rate.

A decrease in flow rate causes the differential pressure across the orifice plate to decrease. The Pilot modulates toward an open position when the differential pressure signal decreases below the control setpoint, causing the Main Valve to modulate toward an open position, increasing flow rate. Turning the adjustment screw clockwise raises the control setpoint, increasing flow rate. Turning the adjustment screw counterclockwise lowers the control setpoint, decreasing flow rate.

The LFCP14-1 is equipped with one %" NPT inlet and two outlet ports for ease of installation, and two ½" NPT sensing ports. The ½" sensing port above the diaphragm is used to monitor the "low pressure" differential signal, and the sensing port below the diaphragm is used to monitor the "high pressure" differential signal.



LFCP14-1

### **Specifications**

Body Material: Lead Free Copper Silicon Alloy

CF8M (316) Stainless Steel (Optional)

Seat: 316 Stainless Steel

Elastomers: Buna-N (standard)

Viton™ (optional) EPDM (optional)


Inlet Pressure Rating: 400psi (27.6 bar) maximum


Viton™ is a trademark of The Chemours Company FC, LLC

<sup>\*</sup>The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.


## **Model LFCP14-1**

## Rate-of-Flow Pilot





Item	Description
1	Spring Housing
2	Spring
3	Cap Screw
4	Power Chamber
5	0-Ring*
6	Body
7	Seat
8	Adjusting Screw
9	Pin
10	Adapter
11	0-Ring *



Description
Spring Guide
Nut
Belleville Washer
Diaphragm Washer
Diaphragm *
0-Ring *
Yoke
Disc & Retainer Assembly*
0-Ring *
Bottom Cap

\*Included in Repair Kit

## **Model S2W**

## 2-Way Solenoid

Size: 1/8" - 1/2" NPT

Model S2W are pilot system 2-way solenoids. The solenoids can control valves independently or in combination with other control circuit pilots or accessories. Product is available with a wide range of options including: voltage (24VDC, 24VAC or 120VAC), operation (energize to open or closed) and a range of enclosures (general service to watertight to explosion proof).

### **Specifications**

Body Material: Brass (standard)

Stainless Steel (optional)

Elastomers: Nitrile (standard)

EPDM (optional)
Viton™ (optional)

Voltage: 24VDC, 24VAC or 120VAC

Enclosure: General Purpose – NEMA 4 (standard)

Explosion Proof – NEMA 6, 6P, 7, 9 (optional)

Action: Normally Open or Normally Closed\*\*

\*\*Solenoid Action only. Main valve action (energize-to-open or energize-to-close) is dependent on the particulars of the pilot system.

\*\*\*Brass solenoids when used as part of a pilot system including an ACV main valve comply with the Lead Free Law.

Viton  $^{\mbox{\tiny TM}}$  is a trademark of The Chemours Company FC, LLC



Model S2W Brass



Model S2W Stainless Steel


## **LEAD FREE\***

## **Model LFFC**

### Flow Control

Size: ½" NPT

A Flow Control is an adjustable device used for tuning valve performance. It can be installed to either control the opening or closing the speed of the automatic control main valve. When the flow is in the direction of the needle the flow control is an adjustable restriction. In the free flow direction the seat moves out of the flow path to all unrestricted flow.





Model LFFC

### **Specifications**

Size: ½" NPT

Body Material: Lead Free Brass

Stainless Steel (optional)

Seat: Lead Free Brass

Needle: Stainless Steel (304)

Elastomers: Buna-N (standard)

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## **LEAD FREE**\*

## **Model BV**


### **Ball Valve**

Size: 1/4" - 1" NPT

Model BV Ball Valves are used in pilot lines to provide a positive shutoff in any override or maintenance situation for simple trouble shooting. This 2-piece, full port valve features: bottom loaded stems, PTFE seats and packing.



Lead Free Ball Valve



Size			Dimens	ions			We	ight
	C			Н		L		
in.	in.	mm	in.	mm	in.	mm	lbs.	kg.
1/4	1 13/16 46		37/16	31/16 87		45	0.4	0.2
3/8	1 <sup>13</sup> / <sub>16</sub>	46	37/16	87	13/4	45	0.4	0.2
1/2	1 <sup>13</sup> / <sub>16</sub>	46	37/16	87	1 <sup>15</sup> / <sub>16</sub>	50	0.4	0.2
3/4	21/4	57	4	101	25/16	59	0.8	0.3

### **Specifications**

Standard Material: Copper Silicon Alloy Body and Adaptor

Chrome Plated Ball

Optional Material: Stainless Steel Housing, Body and Adaptor

Stainless Steel Ball

Pressure Rating: 600psi (41 bar) Non Shock

Temp Rating: -40°F - 400°F

 $^{\star}$ The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## ACV Options and Accessories - Series LFM114-1

## **LEAD FREE\***

## **Model LF60**

## Flo-Clean Strainer


Size: 1/4" - 3/4" NPT

Model LF60 Flo-Clean Strainers are used to filter the fluid passing through the pilot circuit, and provide protection to pilot circuit speed controls and pilots. It is installed in the inlet body port of the Main Valve, exposing the strainer element to main line flow. The currents and flow across the screen create a self-scouring effect, cleaning the filter element.



Model LF60

#### Valve inlet with Filter installed



### **Specifications**


Body Material: Lead Free Brass (standard)

Stainless Steel (optional)

Pressure Rating: 400psi (27.6 bar)

Filter Element: Monel

Screen Mesh: 40 Mesh (standard)



Α	В
Male Pipe Thread	Female Pipe Thread
in.	in.
1/4	1/8
3/8	1/4
1/2	3/8

<sup>\*</sup>The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.


## **LEAD FREE**\*

## **Model LF60-1**

### Y-Pattern Strainer

Size: 1/4" - 3/4" NPT

Model LF60-1 Y-Pattern Strainers are used to filter the fluid passing through the pilot circuit, and provide protection to pilot circuit speed controls and pilots. The filter element can be accessed for cleaning by removing the clean-out cap, or may be cleaned by installing an optional "blow-down" ball valve.



### **Dimensions**

SIZE		DIMENS	IONS		WEI	GHT
	A		I	3		
in.	in	mm	in	mm	lbs.	kgs.
1/4	211/16	68	111/16	43	1.7	0.77
3/8	211/16	68	111/16	43	1.7	0.77
1/2	3	76	2	51	1.7	0.77
3/4	35/16	84	25/16	59	1.7	0.77



Model LF60-1

### **Specifications**

Body Material: Lead Free Copper Silicon Alloy

CF8M (316) Stainless Steel (optional)

Retainer Cap: Lead Free Copper Silicon Alloy

Cap Gasket: EPDM

Pressure Rating: 400psi (27.6 bar)
Filter Element: 304 Stainless Steel
Mesh Options: 60 Mesh (standard)

100 Mesh (optional)

<sup>\*</sup>The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.


## **LEAD FREE\***

## Model 50

## **Position Indicator**

When specified as an option on a Control Valve, the Model 50 Position Indicator is installed in the topmost cover port of the Main Valve and allows for visual indication of valve position. The Model 50 is also very useful during valve start-up and troubleshooting procedures.

A stainless steel indicating rod threads into the tapped portion of the Main Valve stem and moves inside of a cylindrical Pyrex sight tube. The indicating rod travels up and down, following Main Valve stem movement. The housing protects the sight tube and indicating rod, and allows visibility on two sides. The screw driver operated test cock installed on the top of the Model 50 housing provides a controlled method of removal of air from the cover chamber during start-up or troubleshooting of the Main Valve.



Item	Description				
1	Test Cock				
2	Housing				
3	Gasket				
4	Pyrex Sight Tube				
5	Body				
6	Indicating Rod				
7 Stem Adaptor (8" or Larg					



Model LF50

### **Specifications**

Standard Material: Stainless Steel Housing and Body

Stainless Steel Indicating Rod

Lead Free Test Cock Pyrex Sight Tube

Optional Material: Stainless Steel Test Cock

Pressure Rating: 400psi (27.6 bar)

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

#### **Dimensions**

Valve Size (in)	Dimension (in)					
1¼ - 1½	7%					
2	4%					
2½	4%					
3	4%					
4	5					
6	5					
8	5%					
10	5%					
12	71/4					
14	71/4					
16	71/4					
18*	71/4					
20*	71/4					
24*	71/4					

\*Reduced Port


## **LEAD FREE\***

## Model 51


## Single Limit Switch

The Model 51 Single Limit Switch provides visual indication of valve position, as well as remote electrical indication of "valve open" or "valve closed". The single pole double throw Micro-Switch can be connected to open or close an electrical circuit when the valve opens or closes.

The adjustable collar is normally set to contact the trip arm when the main valve is closed. The collar can be positioned on the stem by loosening the set-screw to actuate the switch at the desired point of valve travel.



Single Pole Double Throw Switch





Model LF51

### **Specifications**

Body Material: Stainless Steel

Elastomers: Buna-N (standard)

EPDM (optional) Viton™ (optional)

Enclosure: NEMA 1, 3, 4 and 13 General Purpose (standard)

NEMA 1,7 and 9 Explosion Proof (optional)

Electrical: Form C SPDT Switch

15 amp. 125, 250 or 480 VAC

½ amp. 125 VDC ¼ amp. 250 VDC ½" Conduit Connection

Viton  $^{\text{TM}}$  is a trademark of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

#### Parts List

Item	Description				
1	Limit Switch				
2	Bracket				
3	Stem				
4	Trip collar				
5	Set Screw				
6	Cap				
7	Wiper Ring*				
8	0-Ring*				
9	Guide				
10	0-Ring*				
11	Polypak*				
12	Locknut				
13	Body				
14	Pin				
15	Coupling				


\*Included in Repair Kit


### Installation


Start-up of an automatic control valve requires that proper procedures be followed. Time must be allowed for the valve to react to adjustments and the system to stabilize. The objective is to bring the valve into service in a controlled manner to protect the system from damaging over-pressure.


- 1. Prior to installation, flush line to remove debris.
- 2. Install valve so the flow arrow matches flow through the line, and gauges to monitor valve inlet and outlet pressures. A Position Indicator can be installed to provide visual indication of valve position and operation without disassembly.
- 3. Install isolation valves upstream and downstream of the main valve.
- 4. Provide adequate clearance for valve servicing and maintenance. Refer to valve servicing dimensions on next page. Avoid installing valves 6" and larger in the vertical position (main valve stem horizontal). Automatic Control Valves (ACVs) are designed for horizontal in-line installation, with the cover facing up (main valve stem vertical). Slow operation or premature stem and guide wear may occur if valve is not installed according to factory recommendations. Consult factory for detailed engineering review prior to ordering if valve is to be installed other than horizontally in-line.
- 5. If valve is equipped with a pilot control system, extra precautions should be made during installation to protect the piping circuit from damage. Only remove the pilot control system from the valve if necessary. Tubing and fittings should be kept clean and replaced exactly as removed. Consult appropriate hydraulic schematic to ensure proper re-assembly.
- 6. To accurately set flow rates, either a differential gauge or a flow meter should be installed.
- 7. Check orifice plate to assure that sense holes are free from obstruction.
- 8. Connect solenoid wiring leads to desired switching device, using safe, standard electrical practices.
- After installation, vent entrapped air from valve cover and pilot system by following instructions in the Setting the Rate-of-Flow Controls section on the following page.

## **Valve Servicing Dimensions**









The following tables detail the recommended minimum valve servicing dimensions.

#### Globe

Size (in)	1¼	1½	2	2½	3	4	6	8	10	12	14	16	20	24
A (in)	16	16	20	22	22	24	32	34	38	44	48	52	56	56
B (in)	10	10	12	14	14	16	24	26	28	30	34	40	48	48

#### Angle

Size (in)	11/4	1½	2	2½	3	4	6	8	10	12	14	16
C (in)	16	16	20	22	22	24	32	34	38	44	48	52
D (in)	10	10	12	14	14	16	24	26	28	30	34	40

## **Setting the Rate-of-Flow Control Valves**

#### STEP 1

Pre-set pilots as noted:

Rate of Flow - Adjust OUT, counterclockwise, to start valve at a lower flow rate.

Opening and Closing Speed – Turn the adjustment screws on the Closing Speed and Opening Speed Controls, if the main valve is so equipped, OUT, counterclockwise, 1½ to 2½ turns from full closed position.

#### STEP 2

Energize the solenoid to check actuation and to confirm connection to power source and so that initial valve filling is against the closed solenoid.

#### STEP 3

To ensure proper operation, any trapped air will need to be bled off the valve cover during startup. The ACV includes a bleed valve, use a flat head screwdriver to slowly open the valve (See Figure 1).

#### STEP 4

Pressure the line, by opening the upstream isolation valve slowly. Air is vented through the air bleed valve. Tighten the fitting when liquid begins to vent (See Figure 1).

Repeat the process until no air is trapped in the system.

#### STEP 5

Actuate the solenoid to open the main valve, checking that the main valve opens.



Figure 1
Position Indicator

## **Setting the Rate-of-Flow Control Pilot**

#### STEP 6

Slowly open downstream isolation valve to establish flow through the system.

### STEP 7

With a demand for flow on the system, the valve can now be adjusted for the proper flow rate. This requires a meter to read the flow that the valve is providing.

#### STEP 8

While reading the meter register, adjust the Rate of Flow Control:

Turn the adjustment screw IN, clockwise, to increase the flow rate regulated (See Figure 2A).

Turn the adjustment screw OUT, counterclockwise, to reduce or lower the flow rate regulated (See Figure 2B).

## Clockwise to INCREASE Flow Rate Limit



## Counterclockwise to REDUCE Flow Rate Limit



Figure 2
CP14-1 Rate-of-Flow Control Pilot

#### STEP 9

Opening Speed Flow Control Adjustment: The Opening speed flow control allows free flow into the cover and restricted flow out of the cover of the main valve.

If valve opening is too slow, turn the adjustment screw OUT, counterclockwise, increasing the rate of opening (See Figure 3B).

If valve opening is too quick, turn the adjustment screw IN, clockwise, decreasing the rate of opening (See Figure 3A).

## Clockwise to DECREASE rate of opening

Counterclockwise to INCREASE the rate of opening





Figure 3 Flow Control

### STEP 10

Closing Speed Needle Valve Adjustment: The closing speed needle valve regulates fluid pressure into the main valve cover chamber, controlling the valve closing speed.

If the valve closes too slowly, turn the adjustment screw OUT, counterclockwise, increasing the rate of closing.

#### **STEP 11**

Actuate the solenoid to close the main valve, checking that the main valve closes.

### **Automatic Control Valve Maintenance Schedule**

To ensure peak performance and longevity of your automatic control valve, Watts/Ames recommends following the below standard maintenance schedule.

#### • Monthly Maintenance

- Visual inspection of valve(s) for leaks
- Inspect for proper operation(s); exercise valve.

#### • Quarterly Maintenance

- Conduct monthly inspection.
- Validate/Re-establish necessary setpoints of controls/pilots.

#### Annual Maintenance

- Conduct monthly & quarterly inspections.
- Inspect & clean all strainers.
- Inspect valve coating, touch up as required.

#### • 3-5 Year Maintenance

- Conduct monthly, quarterly, & annual maintenance.
- Inspect & replace valve elastomers (diaphragm, O-rings, valve/pilot seats)
- Re-establish necessary set points of controls/pilots.

## **Troubleshooting Guide**

#### **A** WARNING

**Warning:** The valve cannot be serviced under pressure. Upstream and downstream Isolation Valves must be installed to protect system piping. Accurate diagnosis and trouble-shooting requires the valve to open fully, and may subject downstream piping and equipment to high pressure and/or flow rates. The downstream Isolation Valve should be kept closed while diagnosing the valve.

Extreme caution should be used while performing the troubleshooting techniques listed below.

Recommended tools for diagnosis: (3) PRESSURE GAUGES, installed to monitor the inlet pressure, outlet pressure, and cover chamber pressure. If included, a POSITION INDICATOR should be installed to visually assess the position of the disc & diaphragm assembly.

#### Test 1: Diaphragm Seal Test

- Close upstream & downstream isolation valves. Close pilot isolation valves or remove pilot control tubing to isolate valve cover from incoming fluid & pressure. Remove uppermost cover plug, test cock, or limit switch.
- 2. With the valve cover chamber vented to atmosphere, partially open the upstream isolation valve, allowing incoming pressure to lift the disc & diaphragm assembly. A volume of water will be displaced from the cover chamber as the valve opens; consult valve specification sheets for approximate cover capacity. A continuous flow of water from the open port indicates a damaged diaphragm or loose disc & diaphragm assembly. Disassemble valve and replace diaphragm or tighten disc & diaphragm assembly.

#### Test 2: Seat Seal Test

- 1. Close downstream isolation valve and install pressure gauges on an open inlet and outlet port of main valve.
- Open upstream isolation valve to allow pressure on to the valve cover. Allow valve to fully close.
- 3. Monitor downstream pressure gauge; reading should hold steady below incoming pressure. If pressure on downstream side rises to match upstream pressure, leakage is occurring through the seat of the main valve. Disassemble valve, inspect and repair/replace any required parts.
  - a. If gauge pressure rises to match outlet pressure (downstream of closed isolation valve) yet remains below inlet pressure, the isolation valve may be leaking as opposed to main valve seat.

### Test 3: Freedom of Movement/Valve Travel Test

- Close upstream and downstream isolation valves. Install valve position indicator.
- Partially open upstream isolation valve and allow cover to fill with fluid & pressure, closing the valve fully. Mark the position indicator's full closed position.
- Isolate cover chamber from receiving fluid and pressure by closing isolation valves or removing control tubing.
- 4. Carefully vent cover chamber to atmosphere by opening test cock or removing a cover plug. Observe the valve position indicator as the valve travels to the full-open position. The disc & diaphragm assembly should move freely from fully closed to fully open position without binding or "grabbing" at any point during its movement.
  - a. The disc & diaphragm assembly may momentarily "hesitate" while travelling from fully closed to fully open position

     this is a normal characteristic of diaphragm operated control valves, and does not indicate mechanical binding or improper valve operation.
  - A continuous discharge of water from the cover chamber after venting to atmosphere indicates leakage past the diaphragm.
- If necessary, disassemble valve and inspect/repair disc & diaphragm assembly.


## **Troubleshooting Guide**

Issue	Possible Cause	<b>Corrective Action</b>	Notes
Main Valve will not open	Closed isolation valves in pilot system.	Check isolation valves, ensure open.	
	Insufficient supply pressure.	Check upstream pressure.	Depending on water source, supply pressure may not be controlled by valve operator.
	Main valve stem assembly corroded/ damaged	Inspect stem assembly, clean/ replace if necessary.	
	Blockage in pilot system.	Inspect & clean any installed pilot system strainers, check orifice/speed controls for blockages.	
	Improperly configured opening speed control.	Adjust opening speed control to verify functionality, adjust as required.	Standard setting for opening speed control is 1½ - 2½ turns open from full closed position. Can be adjusted in field.
Main Valve will not close	Closed isolation valves in pilot system	Check isolation valves, ensure open.	
	Diaphragm is damaged	Conduct diaphragm seal test, repair and replace if necessary.	
	Main valve stem assembly corroded/damaged.	Inspect stem assembly, clean/ replace if necessary.	
	Blockage in main valve.	Perform freedom of movement test; if valve does not close, disassemble and remove blockage.	
	Worn/damaged valve seat.	Perform seat sealing check; disassemble and inspect/repair seat if required.	
	Improperly configured closing speed control.	Adjust closing speed control to verify functionality, adjust as required.	Standard setting for closing speed control is 1½ - 2½ turns open from full closed position. Can be adjusted in field.
	Field installed orifice lines are reversed	Reinstall per schematic	
Solenoid will not actuate	Possible Cause: Low or no voltage	Check voltage at the solenoid connection, insuring that it has the minimum of 85% of the coils rated voltage.	Should be performed by licensed electrician


## **Valve Disassembly Instructions**

Before undertaking valve disassembly, it is recommended to gather the following tools to aid you during the process:

- Small & large adjustable wrenches
- Screwdriver set
- Machinist fine metal file
- Fine wire brush
- Bench vise
- Basic valve IO&M manual
- Hammer & dull cold chisel
- Heavy-duty ratchet & socket set
- · Hexagonal wrench set
- 320 grit/fine Emery cloth
- Appropriate technical bulletins for valve start-up procedures.



- 1. Isolate the valve from line pressure and depressurize it to ensure safe working conditions. Disconnect any electrical connections if so equipped.
- 2. Carefully remove Position Indicator or Limit Switches if equipped. Remove all tubing, fittings, and Control Pilots necessary to easily access and remove the cover. Remove cover nuts and washers.
- 3. Remove the cover. If cover is not free to be removed, loosen it by tapping upward along its outside edge with a dull cold chisel, pictured above.
  - a. Large valves may require the installation of lifting "eye" bolts in order to facilitate cover removal; installation ports are provided on the cover for this purpose.
- 4. Remove the Disc and Diaphragm Assembly from the valve body by lifting straight up.
  - a. Large diameter valves may require a lifting "eye" bolt to be installed in the valve stem accessory threads located on the very top of the valve stem.
- 5. Before removing Stem Nut, examine stem threads for mineral build-up. Remove deposits with a fine wire brush. Extreme care should be taken not to damage the finish on stem guiding surfaces when disassembling. Avoid applying pipe wrenches to top or bottom stem guide surfaces.
- 6. After removing the Stem Nut, the remainder of the Disc & Diaphragm Assembly should disassemble easily. Polish stem guide surfaces with fine emery cloth to remove any mineral deposits and inspect for excessive wear. Remove any mineral build-up from other components with wire brush or by using a Mineral Dissolving Solution. Inspect parts for wear and replace if necessary.
- 7. Inspect valve seat. If seat is not damaged, removal is not necessary. Valve seats 6" and smaller are threaded into the body of the valve and require a seat removal tool (Figure 4) (Table 1 details the tool dimensions for seat removal). Valve seats 8" and larger are held in the valve body with stainless steel cap screws. Remove seat retaining screws and lift seat straight up (Figure 5).






Table 1: Seat Removal Tool Dimension

Size	Α	В	C	D	E (Dia.)	F
in	Pipe Size (in)	Min. Length (in)	in	in	in	in
11⁄4	1	3.12	0.38	0.25	0.44	0.55
1½	1	3.12	0.38	0.25	0.44	0.50
2	11⁄4	3.38	0.38	0.25	0.44	0.50
2½	2	4.0	0.38	0.38	0.56	0.62
3	2½	4.5	0.50	0.38	0.56	0.62
4	3	5.0	0.50	0.44	0.56	0.62
6	5	6.50	0.62	0.44	0.56	0.62

<sup>\*</sup>Schedule 40 steel pipe

### Table 2: Full Port Valve (M100/M1100) Repair Kits

Size (in)	11⁄4	1½	2	21/2	3	4	6	8	10	12	14	16
P/N	0677-01	0677-01	0677-02	0677-03	0677-04	0677-05	0677-06	0677-07	0677-08	0677-09	0677-10	0677-11

### Table 3: Reduced Port Valve (M6100 / M61100) Repair Kits

Size (in)	3	4	6	8	10	12	16	20 & 24
P/N	0677-02	0677-04	0677-05	0677-06	0677-07	0677-08	0677-09	0677-11

- 9. Re-Install Disc and Diaphragm Assembly in the valve, taking care not to damage the lower guide area in the center of the valve seat.
- 10. Re-install Cover Spring. Replace Valve Cover and tighten Cover Nuts in a crossing pattern to ensure even distribution. Test the Disc and Diaphragm Assembly for smooth travel by following the Freedom of Movement Test procedure in previous section.
- 11. Test the integrity of the Seat Seal by following the Seat Seal Test procedure in previous section.
- 12. Return valve to service by following instructions in the Setting the Rate-of-Flow Controls section matching the valve function.

<sup>8.</sup> Replace Seat Disc, Diaphragm and Spacer Washers provided in Main Valve repair kit (refer to Table 2 or 3 for correct repair kit part number). Re-assemble in the reverse order of disassembly.

Limited Warranty: Watts Regulator Co. (the "Company") warrants each product to be free from defects in material and workmanship under normal usage for a period of one year from the date of

THE WARRANTY SET FORTH HEREIN IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OTHER WARRANTIES, EXPRESS OR IMPLIED. THE COMPANY HEREBY SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

The remedy described in the first paragraph of this warranty shall constitute the sole and exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged if this product does not work properly, other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water conditions, chemical, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication, improper installation or improper maintenance or alteration of the product.

Some States do not allow limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. Therefore the above limitations may not apply to you. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult applicable state laws to determine your rights. SO FAR AS IS CONSISTENT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED IN DURATION TO ONE YEAR FROM THE DATE OF ORIGINAL SHIPMENT.



**USA:** T: (978) 689-6066 • F: (978) 975-8350 • Watts.com Canada: T: (888) 208-8927 • F: (905) 481-2316 • Watts.ca Latin America: T: (52) 55-4122-0138 • Watts.com

ES-ACV-LFM114-1 2115 © 2021 Watts