## Submittal Package

## Engineering Specification, Installation, Operation and Maintenance Series LF986GD / LF686GD

**Pump Control Valve** 

Sizes: 11/4" to 24"

#### A WARNING



Read this Manual BEFORE using this equipment. Failure to read and follow all safety and use information can result in death, serious personal injury, property damage, or damage to the equipment.

Keep this Manual for future reference.

#### A WARNING

Local building or plumbing codes may require modifications to the information provided. You are required to consult the local building and plumbing codes prior to installation. If the information provided here is not consistent with local building or plumbing codes, the local codes should be followed. This product must be installed by a licensed contractor in accordance with local codes and ordinances.


#### A WARNING

**Need for Periodic Inspection/Maintenance:** This product must be tested periodically in compliance with local codes, but at least once per year or more as service conditions warrant. All products must be retested once maintenance has been performed. Corrosive water conditions and/or unauthorized adjustments or repair could render the product ineffective for the service intended. Regular checking and cleaning of the product's internal and external components helps assure maximum life and proper product function.

#### NOTICE

For Australia and New Zealand: Pipeline strainers should be installed between the upstream shutoff valve and the inlet of the backflow preventer.

It's important that this device be tested periodically in compliance with local codes, but at least once per year or more as service conditions warrant. If installed on a fire sprinkler system, all mechanical checks, such as alarm checks and backflow preventers, should be flow tested and inspected internally in accordance with NFPA 13 and NFPA 25.



LF986GD

#### Table of Contents

#### **Engineering Specifications**

ACV Schematic
Basic Valves
Standard Components7
Optional Components
Installation, Operation and Maintenance
Installation
Valve Servicing Dimensions
Commissioning the Pump Control Valve
ACV Maintenance Schedule 19
Troubleshooting Guide
Valve Disassembly Instructions



Page

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.

A WATTS Brand

## **Engineering Specification**

## LEAD FREE<sup>\*</sup> Series LF986GD

# Pump Control Valve

## Full Port Ductile Iron Single Chamber Valve Features

- Opens at adjustable rate on pump start-up
- Closes at adjustable rate on pump shut-off
- Limit Switch turns pump off when valve closes
- Hydraulic Check Feature prevents flow reversal
- Solenoid equipped with Manual Operator

#### **Standard Components**

- 1 Main Valve (905GD Single Chamber)
- 2 Model 22-1 Accelerator Control
- 3 Limit Switch
- 4 3-Way Solenoid
- 5 Check Valve
- 6 Adjustable Closing Speed
- 7 Adjustable Opening Speed
- Y Y-Strainer
- X Isolation Cocks

### **Options and Accessories**


- O FC Flo-Clean Strainer
- O L Dual Limit Switch

#### Operation

The Pump Control Valve is designed to minimize the surges associated with the starting and stopping of pumps. The valve slowly opens and closes as required to control pumping related surges. The pump starts and stops against a closed valve.

**Pump Start Up:** When the pump is signaled to start, the 3-Way Solenoid is energized, directing pressure into the cover chamber of the 3-way Accelerator Pilot. The Accelerator Pilot allows the main valve cover chamber to be vented downstream, causing the valve to open at a controlled rate, gradually admitting pumping pressure into the distribution system. The rate of opening is controlled by the adjustable opening speed control, which restricts the speed of fluid and pressure evacuating the main valve cover chamber. The valve remains open during the pumping cycle.

**Pump Shutdown:** When the pump is signaled to turn off, the 3-Way Solenoid is de-energized, venting the cover chamber of the 3-way Accelerator Pilot. The Accelerator Pilot allows the main valve cover chamber to be connected to upstream pressure, causing the valve to close at a controlled rate. The valve slowly begins to close while the pump continues to operate. The closing rate of the valve is controlled by the adjustable closing speed control, which restricts the speed of fluid and pressure entering the main valve cover chamber. When the valve reaches the closed position, the limit switch is actuated, turning the pump off.



**Hydraulic Check Feature:** When the pump is turned off and downstream pressure is greater than upstream pressure, downstream pressure is admitted to the main valve cover chamber through a check valve in the pilot control system, closing the valve, preventing reversal of flow.

**Manual Operation:** Engaging the Solenoid Manual operator simulates power to the solenoid, manually opening the main valve. Disengaging the Solenoid Manual operator returns the valve to the closed position.

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

#### NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

## **M Series Basic Valves**

## **Pump Control Valve**

## Full Port Ductile Iron Single Chamber Basic Valve

This Ames Automatic Control Valve (ACV) is a full port, single chamber basic valve that incorporates a one-piece disc and diaphragm assembly. This assembly is the only moving part within the valve allowing it to open, close, or modulate as commanded by the pilot control system.

Ames ACV Main Valves are Lead Free. The Ames ACV piloting system contains Lead Free\* components, ensuring all of our configurations are Lead Free compliant.

Globe Pattern Single Chamber Basic Valve (905GD) Angle Pattern Single Chamber Basic Valve (905AD)

### **Standard Materials**

Body and Cover:	Ductile Iron ASTM A536
-----------------	------------------------

Coating:

NSF Listed Fusion Bonded Epoxy Lined and Coated

Trim:316 Stainless SteelElastomers:Buna-N (standard)

Nut, Spring and Stem:

Buna-N (standard) EPDM (optional) Viton™ (optional)

Stainless Steel



Anti-Scale (Optional): Xylan Coated Stem and Seat

Viton™ is a trademark of The Chemours Company FC, LLC

## **Operating Pressure**

Threaded = 400psi (27.6 bar) 150# Flanged = 250psi (17.2 bar) 300# Flanged = 400psi (27.6 bar) Grooved End = 400psi (27.6 bar)

## **Operating Temperature**

Buna-N: 160°F (71°C) Maximum EPDM: 300°F (140°C) Maximum Viton™: 250°F (121°C) Maximum Epoxy Coating\*\*: 225°F (107°C) Maximum

\*\* Valves can be provided without internal epoxy coating consult factory

## **Basic Valve Body Options**





Globe Flanged







Globe Threaded



Angle Grooved End



Angle Threaded

## Flow Data

Valve Size - Inches	1¼	1½	2	21⁄2	3	4	6	8	10	12	14	16
Maximum Continuous Flow Rate Gpm (Water)	95	130	210	300	485	800	1850	3100	5000	7000	8500	11100
How Kate Gpm (Water) Maximum Intermittent Flow Rate Gpm (Water)	119	161	265	390	590	1000	2300	4000	6250	8900	10800	14100
Minimum Flow Rate Gpm (Water)	3	5	6	9	15	16	17	25	55	70	190	400
Cv Factor GPM (Globe)	26	26	48	75	112	188	387	764	1215	1734	2234	3131
Cv Factor GPM (Angle)	26	27	57	91	125	207	571	889	1530	1945		

- Maximum continuous flow based on velocity of 20 ft. per second.
- Maximum intermittent flow based on velocity of 25 ft. per second.
- Minimum flow rates based on a 20-40 psi pressure drop.
- The C, Factor of a value is the flow rate in US GPM at  $60^{\circ}$ F that will cause a 1psi drop in pressure.
- C<sub>v</sub> factor can be used in the following equations to determine Flow (Q) and Pressure Drop (ΔP):


Q (Flow) =  $C_v \sqrt{\Delta P}$ 

 $\overline{P}$   $\Delta P$  (Pressure Drop) = (Q/C<sub>v</sub>)<sup>2</sup>

• The C<sub>v</sub> factors stated are based upon a fully open valve.

 Many factors should be considered in sizing control valves including inlet pressure, outlet pressure and flow rates.

• For sizing questions including cavitation analysis consult Watts with system details.




#### Valve Cover Chamber Capacity

Valve Size - Inches	1¼	1½	2	21⁄2	3	4	6	8	10	12	14	16
fl.oz.	4	4	4	10	16	22	70					
U.S. Gal								1¼	21⁄2	4	6½	91⁄2

#### Valve Travel

Valve Size - Inches	1¼	1½	2	21⁄2	3	4	6	8	10	12	14	16
Travel - Inches	3⁄8	3⁄8	1⁄2	5⁄8	3⁄4	1	1½	2	21⁄2	3	3½	4


### **Basic Valve**



Item	Description	Material
1	Pipe Plug	Lead Free Brass
2	Cover	ASTM A536 65-45-12 Epoxy Coated Ductile Iron
3	Cover Bearing	ASTM A276 304 Stainless Steel
4	Stud with Cover Nut and Washer	ASTM A570 Gr.33 Zinc Plated Steel
5	Body	ASTM A536 65-45-12 Epoxy Coated Ductile Iron
6	Spring	ASTM A276 302 Stainless Steel
7	Stem Nut	ASTM A276 304 Stainless Steel
8	Lock Washer	ASTM A276 304 Stainless Steel
9	Stem Washer	ASTM A276 304 Stainless Steel
10	Diaphragm Washer	ASTM A536 65-45-12 Epoxy Coated Ductile Iron
11	Diaphragm*	Buna-N (Nitrile)
12	Disc Retainer	ASTM A536 65-45-12 Epoxy Coated Ductile Iron
13	Seat Disc*	Buna-N (Nitrile)
14	Spacer Washer* x5	NY300 Fiber*
15	Disc Guide	ASTM A743 CF8M (316) Stainless Steel
16	Shaft	ASTM A276 304 Stainless Steel
17	Seat Ring**	ASTM A743 CF8M (316) Stainless Steel
17A	Seat Screw** (8" and Larger)	ASTM A276 304 Stainless Steel
18	Seat Gasket*	Buna-N (Nitrile)

\* Contained in Main Valve Repair Kit


\*\*Note: 6 inch and Smaller Valves, Seat Ring is threaded



#### NOTICE

Installation: If unit is installed in any orientation other than horizontal (cover up) OR extreme space constraints exist, consult customer service prior to or at the time of order.

## Dimensions



#### Flanged and Threaded Dimensions

Valve Size	Globe	Thread	Globe	150#	Globe	300#		er To 1ter	Angle	Thread	Angle	150#	Angle	300#	Angle <sup>*</sup>	Thread	Angle	150#	Angle	300#	Port Size NPT	Port Size NPT	Ship Weig	
	4	4	E	3	(	2	[	)	l	-	F	:	(	3	ŀ	-					K	L		
in.	in.	тт	in.	mm	in.	mm	in.	mm	in.	mm	in.	тт	in.	mm	in.	mm	in.	тт	in.	тт	in.	in.	lbs.	kgs.
1¼	7¼	184					5½	140													3⁄8	1⁄4	20	9
1½	7¼	184	81⁄2	216			5½	140	3¼	83					1%	48					3⁄8	1⁄4	25	11
2	9%	238	9%	238	10	254	6¾	171	4¾	120	4¾	121	5	127	3¼	83	3¼	83	31⁄2	89	3⁄8	1/2	40	18
21/2	11	279	11	279	11%	295	7½	191	5½	140	5½	140	5%	149	4	102	4	102	4 5⁄16	110	1/2	1/2	65	29
3	121⁄2	318	12	305	13¼	337	8¼	210	6¼	159	6	152	6%	162	41⁄2	114	4	102	4%	111	1/2	1/2	95	43
4			15	381	15%	397	10%	270			71⁄2	191	7%	200			5	127	55/16	135	3⁄4	3⁄4	190	86
6			20	508	21	533	13	330			10	254	101⁄2	267			6	152	6½	165	3⁄4	3⁄4	320	145
8			25%	645	26%	670	16	406			12¾	324	13¼	337			8	203	81⁄2	216	1	1	650	295
10			29¾	756	311/8	791	17	430			14%	378	15%	395			8%	219	9 <sup>5</sup> ⁄16	237	1	1	940	426
12			34	864	35½	902	20%	530			17	432	17¾	451			13¾	349	14½	368	1	1¼	1500	680
14			39	991	40½	1029	24¼	616													1	1½	1675	760
16			41 %	1051	431⁄2	1105	25¼	640													1	2	3100	1406

#### Grooved End Dimensions

Valve Size	Globe G	Grooved	Cover T	o Center	Angle (	Grooved	Angle (	Grooved	Port Size (npt)	Port Size (npt)	Shipping	Weights*
		4	I	В		C	I	D	E	F		
in.	in.	mm	in.	тт	in.	тт	in.	тт	in.	in.	lbs.	kgs.
1¼	81⁄2	216	5½	140	4¼	108	3¼	83	3⁄8	1⁄4	25	11
1½	8½	216	5½	140	4¼	108	3¼	83	3⁄8	1⁄4	25	11
2	9	229	6½	165	4¾	121	3¼	83	3⁄8	1/2	40	18
21/2	11	279	7½	191	5½	140	4	102	1/2	1/2	65	29
3	12½	318	8¼	210	6	152	4¼	108	1/2	1/2	95	43
4	15	381	10%	270	7½	191	5	127	3⁄4	3⁄4	190	86
6	20	508	13%	340					3⁄4	3⁄4	320	145
8	25%	645	16	406					1	1	650	295

## EAD FRE

## **Model 22-1 3-Way Accelerator Control**

#### Size: 1/2"

The Model 22-1 3-Way Accelerator Pilot is a diaphragm-actuated control with three separate ports: Supply, Common and Exhaust. It is normally installed in the pilot control circuit of an Automatic Control Valve, with the supply port connected to upstream pressure, the common port connected to the Main Valve cover chamber, and the exhaust port vented either downstream or to atmosphere. Its large 1/2" ports offer increased capacity, and allow smaller ported devices, such as a 3-Way Solenoid, Float or Altitude Pilot, to operate the Main Valve open and closed.

When the cover of the Accelerator Pilot is de-pressurized, the main valve cover chamber is connected to upstream pressure, causing the valve to close drip tight.

When the cover of the Accelerator Pilot is pressurized, the main valve cover chamber is vented downstream (dry drain) or to atmosphere (wet drain), causing the valve to open fully.



Model LF22-1


Specifications	
Size:	1⁄2"
Body Material:	C87800 Silicone Bronze (std) CF8M Stainless Steel (opt)
Elastomers:	Buna-N (std) Viton™ (opt) EPDM (opt)
Inlet Pressure Rating:	400 psi maximum
	Size: Body Material: Elastomers:

Viton<sup>™</sup> is a trademark of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

ltom	Description
Item	Description
1	Nut
2	Lock Washer
3	Upper Diaphragm
4	Diaphragm*
5	Lower Diaphragm Washer
6	Spring
7	Stem
8	Spool
9	0-Ring*
10	0-Ring*
11	Retainer
12	0-Ring*
13	0-Ring Washer
14	Lock Washer
15	Nut

\*Included in Repair Kit




## LEAD FREE\*


## Model 51 Single Limit Switch

The Model 51 Single Limit Switch provides visual indication of valve position, as well as remote electrical indication of "valve open" or "valve closed". The single pole double throw Micro-Switch can be connected to open or close an electrical circuit when the valve opens or closes.

The adjustable collar is normally set to contact the trip arm when the main valve is closed. The collar can be positioned on the stem by loosening the set-screw to actuate the switch at the desired point of valve travel.



Single Pole Double Throw Switch





Model LF51

### **Specifications**

Body Material:	Stainless Steel
Elastomers:	Buna-N (standard) EPDM (optional) Viton™ (optional)
Enclosure:	NEMA 1, 3, 4 and 13 General Purpose (standard) NEMA 1,7 and 9 Explosion Proof (optional)
Electrical:	Form C SPDT Switch 15 amp. 125, 250 or 480 VAC ½ amp. 125 VDC ¼ amp. 250 VDC ½" Conduit Connection

Viton™ is a trademark of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

#### Parts List

Item	Description
1	Limit Switch
2	Bracket
3	Stem
4	Trip collar
5	Set Screw
6	Сар
7	Wiper Ring*
8	O-Ring*
9	Guide
10	O-Ring*
11	Polypak*
12	Locknut
13	Body
14	Pin
15	Coupling
	*Included in Penair Kit

\*Included in Repair Kit

## **Model S3W**

## 3-Way Solenoid

## Size: 1/8" - 1/2" NPT

Model S3W are pilot system 3-way solenoids. The solenoids can control valves independently or in combination with other control circuit pilots or accessories. Product is available with a wide range of options including: voltage (24VDC, 24VAC or 120VAC), operation (energize to open or closed) and a range of enclosures (general service to watertight to explosion proof).



### **Specifications**

Body Material:	Brass (standard)*** Stainless Steel (optional)
Elastomers:	Nitrile (standard) EPDM (optional) Viton™ (optional)
Voltage:	24VDC, 24VAC or 120VAC
Enclosure:	General Purpose – NEMA 4 (standard) Explosion Proof – NEMA 6, 6P, 7, 9 (optional)
Action:	Normally Open or Normally Closed**


\*\*Solenoid Action only. Main valve action (energize-to-open or energize-to-close) is dependent on the particulars of the pilot system.


\*\*\*Brass solenoids are not lead free and it is illegal to use them in potable services in the United States such as drinking water, handwashing, food preparation, and dishwashing. However, brass solenoids may be used as a replacement component in a lead free Watts ACV main valve, as the wetted surface of a lead free Watts ACV main valve including installed brass solenoids contains less than 0.25% of lead by weight.

Viton™ is a trademark of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

### Manual Operator





Normal Operating Condition

Manual Override




## **Model CK**

## Check Valve

### Size: 1/4" - 1" NPT

Model CK Check Valves are pilot line check valves. In typical applications these low cracking pressure in-line checks provide a hydraulic check feature to a pilot system. When the main valve outlet pressure exceeds inlet pressure, fluid is directed from the outlet to the main valve cover. This causes the main valve to close until inlet pressure is again greater than outlet.





Model LFCK

### **Specifications**

Standard Material:	Brass Housing and Body Stainless Steel Indicating Rod
Optional Material:	Stainless Steel Housing and Body Disc Viton™ (¼" – ½") PTFE (1")
Pressure Rating:	400psi (27.6 bar)

Viton<sup>™</sup> is a trademark of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.




## **Model LFFC**

## **Flow Control**

### Size: Standard Flow - ½" MNPTx ¾" FNPT High Flow - ½" MxF NPT

A Flow Control is an adjustable device used for tuning valve performance. It can be installed to either control the opening or closing the speed of the automatic control main valve. When the flow is in the direction of the needle the flow control is an adjustable restriction. In the free flow direction the seat moves out of the flow path to all unrestricted flow.








Large Flow Control


Standard Flow Control

#### **Specifications**

Size:	Standard Flow - ½" MNPT x 3%" FNPT High Flow - ½" MXF NPT
Body Material:	Lead Free Brass Stainless Steel (optional)
Seat:	Lead Free Brass
Needle:	Stainless Steel (304)
Elastomers:	Buna-N (standard)

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.








## Model LF60-1

## **Y-Pattern Strainer**

## Size: 1/4" - 3/4" NPT

Model LF60-1 Y-Pattern Strainers are used to filter the fluid passing through the pilot circuit, and provide protection to pilot circuit speed controls and pilots. The filter element can be accessed for cleaning by removing the clean-out cap, or may be cleaned by installing an optional "blow-down" ball valve.





Model LF60-1

#### **Specifications**

Body Material:	Lead Free Copper Silicon Alloy CF8M (316) Stainless Steel (optional)
Retainer Cap:	Lead Free Copper Silicon Alloy
Cap Gasket:	EPDM
Pressure Rating:	400psi (27.6 bar)
Filter Element:	304 Stainless Steel
Mesh Options:	60 Mesh (standard) 100 Mesh (optional)

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## Dimensions

SIZE		WEIGHT				
	A		E	3		
in.	in	mm	in	mm	lbs.	kgs.
1⁄4	2 <sup>11</sup> ⁄16	68	1 <sup>11</sup> /16	43	1.7	0.77
3⁄8	2 <sup>11</sup> /16	68	1 <sup>11</sup> /16	43	1.7	0.77
1/2	3	76	2	51	1.7	0.77
3⁄4	35⁄16	84	<b>2</b> <sup>5</sup> ⁄16	59	1.7	0.77



## **Model BV**


## **Ball Valve**

## Size: 1/4" - 1" NPT

Model BV Ball Valves are used in pilot lines to provide a positive shutoff in any override or maintenance situation for simple trouble shooting. This 2-piece, full port valve features: bottom loaded stems, PTFE seats and packing.



Lead Free Ball Valve



Size		Weight						
	C	C		Н		L		
in.	in.	mm	in.	mm	in.	mm	lbs.	kg.
1⁄4	1 <sup>13</sup> ⁄16	46	37⁄16	87	1 3⁄4	45	0.4	0.2
3⁄8	1 <sup>13</sup> ⁄16	46	37⁄16	87	1¾	45	0.4	0.2
1/2	1 <sup>13</sup> ⁄16	46	37⁄16	87	1 <sup>15</sup> ⁄16	50	0.4	0.2
3⁄4	2¼	57	4	101	25⁄16	59	0.8	0.3

#### **Specifications**

Standard Material:	Copper Silicon Alloy Body and Adaptor Chrome Plated Ball
Optional Material:	Stainless Steel Housing, Body and Adaptor Stainless Steel Ball
Pressure Rating:	600psi (41 bar) Non Shock
Temp Rating:	-40°F - 400°F

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## ACV Options and Accessories - Series LF986GD



## **Model LF60**


## **Flo-Clean Strainer**

## Size: 1/4" - 3/4" NPT

Model LF60 Flo-Clean Strainers are used to filter the fluid passing through the pilot circuit, and provide protection to pilot circuit speed controls and pilots. It is installed in the inlet body port of the Main Valve, exposing the strainer element to main line flow. The currents and flow across the screen create a self-scouring effect, cleaning the filter element.




Model LF60



## Valve inlet with Filter installed

#### **Specifications**

Body Material:	Lead Free Brass (standard) Stainless Steel (optional)
Pressure Rating:	400psi (27.6 bar)
Filter Element:	Monel
Screen Mesh:	40 Mesh (standard)



А	В
Male Pipe Thread	Female Pipe Thread
in.	in.
1⁄4	1⁄8
3⁄8	1⁄4
1/2	3⁄8

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## ACV Options and Accessories - Series LF986GD




## **Model 51-1**

## **Dual Limit Switch**

### Size: 2" - 8" NPT

The Model 51-1 Dual Limit Switch provides visual indication of valve position, as well as remote electrical indication of "valve open" and "valve closed". The single pole double throw Micro-Switches can be connected to open or close an electrical circuit when the valve opens or closes.

The adjustable collars are normally set to contact the trip arms to indicate "valve open" and "valve closed". The collars can be positioned on the stem by loosening the set-screws to actuate the switches at the desired point of valve travel.





Model LF51-1

### **Specifications**

Body Material:	Stainless Steel
Elastomers:	Buna-N (standard) EPDM (optional) Viton™ (optional)
Enclosure:	NEMA 1, 3, 4 and 13 General Purpose (standard) NEMA 1,7 and 9 Explosion Proof (optional)
Electrical:	Form C SPDT Switch 15 amp. 125, 250 or 480 VAC ½ amp. 125 VDC ¼ amp. 250 VDC ½" Conduit Connection
Viton™ is a trademar	k of The Chemours Company FC, LLC

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## Parts List

ltem	Description	
1	Limit Switch	
2	Bracket	
3	Stem	
4	Trip collar	
5	Set Screw	
6	Сар	
7	Wiper Ring*	
8	0-Ring*	
9	Guide	
10	0-Ring*	
11	Polypak*	
12	Locknut	
13	Body	
14	Pin	
15	Coupling	


\*Included in Repair Kit

## Installation

Start-up of an automatic control valve requires that proper procedures be followed. Time must be allowed for the valve to react to adjustments and the system to stabilize. The objective is to bring the valve into service in a controlled manner to protect the system from damaging over-pressure.

- 1. Prior to installation, flush line to remove debris.
- 2. Install valve so the flow arrow matches flow through the line, and gauges to monitor valve inlet and outlet pressures.
- 3. Install isolation valves upstream and downstream of the main valve.
- 4. Provide adequate clearance for valve servicing and maintenance. Refer to valve servicing dimensions on next page. Avoid installing valves 6" and larger in the vertical position (main valve stem horizontal). Automatic Control Valves (ACVs) are designed for horizontal in-line installation, with the cover facing up (main valve stem vertical). Slow operation or premature stem and guide wear may occur if valve is not installed according to factory recommendations. Consult factory for detailed engineering review prior to ordering if valve is to be installed other than horizontally in-line.
- 5. If valve is equipped with a pilot control system, extra precautions should be made during installation to protect the piping circuit from damage. Only remove the pilot control system from the valve if necessary. Tubing and fittings should be kept clean and replaced exactly as removed. Consult appropriate hydraulic schematic to ensure proper re-assembly.
- 6. Connect solenoid wiring leads to desired switching device, using safe, standard electrical practices.
- 7. Wire the limit switch contacts to the proper relay connections, using safe, standard electrical practices. Adjust the limit switch collar to the approximate make/break contact position.
- 8. After installation, vent entrapped air from valve cover and pilot system by following instructions in the **Commissioning the Pump Control Valve** section on the following page.

## **Valve Servicing Dimensions**



The following tables detail the recommended minimum valve servicing dimensions.

#### Globe

Size (in)	1¼	1½	2	<b>2½</b>	3	4	6	8	10	12	14	16	20	24
A (in)	16	16	20	22	22	24	32	34	38	44	48	52	56	56
B (in)	10	10	12	14	14	16	24	26	28	30	34	40	48	48

#### Angle

Size (in)	1¼	1½	2	<b>2½</b>	3	4	6	8	10	12	14	16
C (in)	16	16	20	22	22	24	32	34	38	44	48	52
D (in)	10	10	12	14	14	16	24	26	28	30	34	40

## Installation, Operation and Maintenance - Series LF986GD

## **Commissioning the Pump Control Valve**

NOTE: System needs to be filled, pressurized, and ready for flow

### STEP 1

Pre-set pilots as noted:

Opening and Closing Speed – Turn the adjustment screws on the Closing Speed and Opening Speed Controls, if the main valve is so equipped, OUT, counterclockwise, 1½ to 2½ turns from full closed position.

3-Way Solenoid Valve - Turn manual operator stem counter-clockwise to full out position (See Figure 1).

## STEP 2

Energize the solenoid to check actuation and to confirm connection to power source.

## STEP 3

De-energize the solenoid prior to initial pump start.

### STEP 4

Loosen a tube fitting or cover plug at the main valve to allow air to vent during start-up.



Figure 1 3-Way Solenoid

## STEP 5


Energize the solenoid at pump start to open the main valve, checking that the main valve opens. Air is vented through the loosened fitting. Tighten the fitting when liquid begins to vent.

## STEP 6

Opening Speed Flow Control Adjustment: The Opening speed needle valve restricts flow into the cover and restricted flow out of the cover of the main valve.

If valve opening is too slow, turn the adjustment screw OUT, counterclockwise, increasing the rate of opening (See Figure 2B).

If valve opening is too quick, turn the adjustment screw IN, clockwise, decreasing the rate of opening (See Figure 2A).



## Installation, Operation and Maintenance - Series LF986GD

### STEP 7

De-energize solenoid to check that the main valve closes.

## STEP 8

Closing Speed Needle Valve Adjustment: The closing speed needle valve regulates fluid pressure into the main valve cover chamber, controlling the valve closing speed.

If valve closing is too slow, turn the adjustment screw OUT, counterclockwise, increasing the rate of closing.

### STEP 9

At valve closure booster pump will stop. Adjust limit switch collar to final position to ensure positive actuation of limit switch electrical contact, if necessary, by sliding up/down to location. (See Figure 3).



Figure 3 Limit Switch in Closed Position

## **Automatic Control Valve Maintenance Schedule**

To ensure peak performance and longevity of your automatic control valve, Watts/Ames recommends following the below standard maintenance schedule.

- Monthly Maintenance
  - Visual inspection of valve(s) for leaks
  - Inspect for proper operation(s); exercise valve.

#### • Quarterly Maintenance

- Conduct monthly inspection.
- Validate/Re-establish necessary setpoints of controls/pilots.

#### Annual Maintenance

- Conduct monthly & quarterly inspections.
- Inspect & clean all strainers.
- Inspect valve coating, touch up as required.

#### • 3-5 Year Maintenance

- Conduct monthly, quarterly, & annual maintenance.
- Inspect & replace valve elastomers (diaphragm, O-rings, valve/pilot seats)
- Re-establish necessary set points of controls/pilots.

## **Troubleshooting Guide**

#### A WARNING

**Warning:** The valve cannot be serviced under pressure. Upstream and downstream Isolation Valves must be installed to protect system piping. Accurate diagnosis and troubleshooting requires the valve to open fully, and may subject downstream piping and equipment to high pressure and/or flow rates. The downstream Isolation Valve should be kept closed while diagnosing the valve.

Extreme caution should be used while performing the troubleshooting techniques listed below.

Recommended tools for diagnosis: (3) PRESSURE GAUGES, installed to monitor the inlet pressure, outlet pressure, and cover chamber pressure. If included, a POSITION INDICATOR should be installed to visually assess the position of the disc & diaphragm assembly.

#### Test 1: Diaphragm Seal Test

- 1. Close upstream & downstream isolation valves. Close pilot isolation valves or remove pilot control tubing to isolate valve cover from incoming fluid & pressure. Remove uppermost cover plug, test cock, or limit switch.
- 2. With the valve cover chamber vented to atmosphere, partially open the upstream isolation valve, allowing incoming pressure to lift the disc & diaphragm assembly. A volume of water will be displaced from the cover chamber as the valve opens; consult valve specification sheets for approximate cover capacity. A continuous flow of water from the open port indicates a damaged diaphragm or loose disc & diaphragm assembly. Disassemble valve and replace diaphragm or tighten disc & diaphragm assembly.

### Test 2: Seat Seal Test

- 1. Close downstream isolation valve and install pressure gauges on an open inlet and outlet port of main valve.
- 2. Open upstream isolation valve to allow pressure on to the valve cover. Allow valve to fully close.
- 3. Monitor downstream pressure gauge; reading should hold steady below incoming pressure. If pressure on downstream side rises to match upstream pressure, leakage is occurring through the seat of the main valve. Disassemble valve, inspect and repair/replace any required parts.
  - a. If gauge pressure rises to match outlet pressure (downstream of closed isolation valve) yet remains below inlet pressure, the isolation valve may be leaking as opposed to main valve seat.

#### Test 3: Freedom of Movement/Valve Travel Test

- 1. Close upstream and downstream isolation valves. Install valve position indicator.
- 2. Partially open upstream isolation valve and allow cover to fill with fluid & pressure, closing the valve fully. Mark the position indicator's full closed position.
- 3. Isolate cover chamber from receiving fluid and pressure by closing isolation valves or removing control tubing.
- 4. Carefully vent cover chamber to atmosphere by opening test cock or removing a cover plug. Observe the valve position indicator as the valve travels to the full-open position. The disc & diaphragm assembly should move freely from fully closed to fully open position without binding or "grabbing" at any point during its movement.
  - a. The disc & diaphragm assembly may momentarily "hesitate" while travelling from fully closed to fully open position

     this is a normal characteristic of diaphragm operated control valves, and does not indicate mechanical binding or improper valve operation.
  - b. A continuous discharge of water from the cover chamber after venting to atmosphere indicates leakage past the diaphragm.
- 5. If necessary, disassemble valve and inspect/repair disc & diaphragm assembly.


## **Troubleshooting Guide**

Issue	Possible Cause	<b>Corrective Action</b>	Notes	
Main Valve will not open	Closed isolation valves in pilot system.	Check isolation valves, ensure open.		
	Insufficient supply pressure.	Check upstream pressure.	Depending on water source, supply pressure may not be controlled by valve operator.	
	Main valve stem assembly corroded/ damaged	Inspect stem assembly, clean/ replace if necessary.		
	Blockage in pilot system.	Inspect & clean any installed pilot system strainers, check orifice/speed controls for blockages.		
	Improperly configured opening speed control.	Adjust opening speed control to verify functionality, adjust as required.	Standard setting for opening speed control is 1½ - 2½ turns open from full closed position. Can be adjusted in field.	
Main Valve will not close	Closed isolation valves in pilot system	Check isolation valves, ensure open.		
	Diaphragm is damaged	Conduct diaphragm seal test, repair and replace if necessary.		
	Main valve stem assembly corroded/ damaged.	Inspect stem assembly, clean/ replace if necessary.		
	Blockage in main valve.	Perform freedom of movement test; if valve does not close, disassemble and remove blockage.		
	Worn/damaged valve seat.	Perform seat sealing check; disassemble and inspect/re- pair seat if required.		
	Improperly configured closing speed control.	Adjust closing speed control to verify functionality, adjust as required.	Standard setting for closing speed control is $1\frac{1}{2} - 2\frac{1}{2}$ turns open from full closed position. Can be adjusted in field.	
Solenoid will not actuate	Possible Cause: Low or no voltage	Check voltage at the solenoid connection, insuring that it has the minimum of 85% of the coils rated voltage.	Should be performed by licensed electrician	
	Manual operated is engaged	Turn manual operator counter- clockwise to disengage		


## **Valve Disassembly Instructions**

Before undertaking valve disassembly, it is recommended to gather the following tools to aid you during the process:

- Small & large adjustable wrenches
- Screwdriver set
- Machinist fine metal file
- Fine wire brush
- Bench vise
- Basic valve IO&M manual
- Hammer & dull cold chisel
- Heavy-duty ratchet & socket set
- Hexagonal wrench set
- 320 grit/fine Emery cloth
- Appropriate technical bulletins for valve start-up procedures.



- 1. Isolate the valve from line pressure and depressurize it to ensure safe working conditions. Disconnect any electrical connections if so equipped.
- 2. Carefully remove Position Indicator or Limit Switches if equipped. Remove all tubing, fittings, and Control Pilots necessary to easily access and remove the cover. Remove cover nuts and washers.
- 3. Remove the cover. If cover is not free to be removed, loosen it by tapping upward along its outside edge with a dull cold chisel, pictured above.
  - a. Large valves may require the installation of lifting "eye" bolts in order to facilitate cover removal; installation ports are provided on the cover for this purpose.
- 4. Remove the Disc and Diaphragm Assembly from the valve body by lifting straight up.
  - a. Large diameter valves may require a lifting "eye" bolt to be installed in the valve stem accessory threads located on the very top of the valve stem.
- 5. Before removing Stem Nut, examine stem threads for mineral build-up. Remove deposits with a fine wire brush. Extreme care should be taken not to damage the finish on stem guiding surfaces when disassembling. Avoid applying pipe wrenches to top or bottom stem guide surfaces.
- 6. After removing the Stem Nut, the remainder of the Disc & Diaphragm Assembly should disassemble easily. Polish stem guide surfaces with fine emery cloth to remove any mineral deposits and inspect for excessive wear. Remove any mineral build-up from other components with wire brush or by using a Mineral Dissolving Solution. Inspect parts for wear and replace if necessary.
- 7. Inspect valve seat. If seat is not damaged, removal is not necessary. Valve seats 6" and smaller are threaded into the body of the valve and require a seat removal tool (Figure 4) (Table 1 details the tool dimensions for seat removal). Valve seats 8" and larger are held in the valve body with stainless steel cap screws. Remove seat retaining screws and lift seat straight up (Figure 5).






Figure 5

## Installation, Operation and Maintenance - Series LF986GD

#### Table 1: Seat Removal Tool Dimension

Size	A	В	C	D	E (Dia.)	F
in	Pipe Size (in)	Min. Length (in)	in	in	in	in
1¼	1	3.12	0.38	0.25	0.44	0.55
1½	1	3.12	0.38	0.25	0.44	0.50
2	1¼	3.38	0.38	0.25	0.44	0.50
21⁄2	2	4.0	0.38	0.38	0.56	0.62
3	21/2	4.5	0.50	0.38	0.56	0.62
4	3	5.0	0.50	0.44	0.56	0.62
6	5	6.50	0.62	0.44	0.56	0.62

\*Schedule 40 steel pipe

8. Replace Seat Disc, Diaphragm and Spacer Washers provided in Main Valve repair kit (refer to Table 2 or 3 for correct repair kit part number). Re-assemble in the reverse order of disassembly.

### Table 2: Full Port Valve (905GD/905AD) Repair Kits

Size (in)	1¼	1½	2	21⁄2	3	4	6	8	10	12	14	16
P/N	0677-01	0677-01	0677-02	0677-03	0677-04	0677-05	0677-06	0677-07	0677-08	0677-09	0677-10	0677-11

#### Table 3: Reduced Port Valve (605GD/605AD) Repair Kits

Size (in)	3	4	6	8	10	12	16	20 & 24
P/N	0677-02	0677-04	0677-05	0677-06	0677-07	0677-08	0677-09	0677-11

9. Re-Install Disc and Diaphragm Assembly in the valve, taking care not to damage the lower guide area in the center of the valve seat.

10. Re-install Cover Spring. Replace Valve Cover and tighten Cover Nuts in a crossing pattern to ensure even distribution. Test the Disc and Diaphragm Assembly for smooth travel by following the Freedom of Movement Test procedure in previous section.

11. Test the integrity of the Seat Seal by following the Seat Seal Test procedure in previous section.

12. Return valve to service by following instructions in the Commissioning the Pump Control Valve section matching the valve function.

Limited Warranty: Ames Fire & Waterworks (the "Company") warrants each product to be free from defects in material and workmanship under normal usage for a period of one year from the date of original shipment. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge.

THE WARRANTY SET FORTH HEREIN IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OTHER WARRANTIES, EXPRESS OR IMPLIED. THE COMPANY HEREBY SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

The remedy described in the first paragraph of this warranty shall constitute the sole and exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged if this product does not work properly, other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water conditions, chemical, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication, improper installation or improper maintenance or alteration of the product.

Some States do not allow limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. Therefore the above limitations may not apply to you. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult applicable state laws to determine your rights. So FAR AS IS CONSTENT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MARKENTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MARKENTIES THAT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MARKENTIES THAT HAT NOT AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED IN DURATION TO ONE YEAR FROM THE DATE OF ORIGINAL SHIPMENT.



A WATTS Brand

USA: Backflow T: (978) 689-6066 • F: (978) 975-8350 • AmesFireWater.com USA: Control Valves T: (713) 943-0688 • F: (713) 944-9445 • AmesFireWater.com Canada: T: (888) 208-8927 • F: (905) 481-2316 • AmesFireWater.ca Latin America: T: (52) 55-4122-0138 • AmesFireWater.com